



RFQ 2012 - 04 – Adsorption Clarifier Media

The City of Dawson Creek is requesting quotations for the supply and delivery of 700 cubic feet of Adsorption Clarifier Media.

All documents are available through the City of Dawson Creek website at www.dawsoncreek.ca. The Proponent is solely responsible for ensuring any addenda are downloaded, reviewed, and included in their bid.

Inquiries regarding this Request for Quotations may be directed to John Kalinczuk, Water and Environmental Manager, at 250.782. 3114.

Quotations will be evaluated on the basis of price and other factors, as determined by the City of Dawson Creek purchasing policy. Bidders must refer to the Contract Documents for the terms governing the Bid process. The City reserves the right to accept or reject all or any bids and to waive any informality, incompleteness or error in any bid.

Quotations shall be submitted on the approved form, sealed in an opaque envelope, clearly marked with the supplier's name and **RFQ 2012 – 04 – Adsorption Clarifier Media** and will be accepted up to **2:00 pm local time, Monday, March 5, 2012**, and will be received by:

Tyra Henderson, Deputy Director of Corporate Administration
City of Dawson Creek, Box 150
10105 - 12A Street, Dawson Creek, BC V1G 4G4

It is the sole responsibility of the Bidder to ensure that its Bid is received at the above location and by the time stipulated. Bids received after the stipulated time will be rejected and returned to the Bidder unopened. Faxed Bids are not acceptable and will be rejected.

Specifications/ Scope of Work

Supply and delivery to the Dawson Creek Water Treatment Plant on or before March 30, 2012 (2928 Water Treatment Rd.) of 700 cubic feet (approximately 24,000 lbs) of adsorption clarifier media which meets the following specifications:

- Polyethylene
- ASTM Standard compliant
- Antioxidant Additive
- UV Stabilizer Additive
- Low temperature impact resistant
- High ESCR (stress crack resistant)
- Medium Density
- Tank/Marine Application
- NSF 14, NSF 24, NSF 61, FDA 21 CFR 177.1520 (Agency Ratings)
- Pellet Form
- Rotational Molded
- Specific Gravity (0.937sp gr 23/23°Celsius)
- MFR (190°Celsius/2.16kg) 5.00g/10min
- Tensile Strength 2510 psi
- Flexural Modulus 113000 psi
- DTUL@264psi-unannealed 99.1F
- DTUL@66psi-unannealed 117F
- ARM Low Temperature Impact, ARM Method, 0.125 in:67.8J
- ARM Low Temperature Impact, ARM Method, 0.25 in:217J

RFQ 2012 – 04 – ADSORPTION CLARIFIER MEDIA BID FORM

Completion/Delivery Date: March 30, 2012

*PRICE	
Applicable taxes	
Total	

***Price shall include all shipping, permits and fees, with applicable taxes shown separately.**

Bidders are reminded to complete the pricing section shown above in order to be considered.

Name of Firm Bidding: _____

Authorized Signature: _____ Print Name: _____

Address: _____

City: _____ Postal Code: _____

Phone #: _____ Fax #: _____

E-Mail Address: _____

The undersigned **BIDDER**, having carefully examined the Documents, including the locality and timeline of the proposed work, and having full knowledge of the materials to be furnished, hereby agrees to provide all necessary materials, and fulfil everything that is set forth in strict accordance with Request for Quotations 2012-04 and Addendums numbered #_____, #_____, #_____, for the prices stated in this Bid Submission Form.

Except as expressly and specifically permitted in these Instructions to Bidders, no Bidder shall have any claim for any compensation of any kind whatsoever, as a result of participating in the Request for Quotations, and by submitting a bid, each bidder shall be deemed to have agreed that is has no claim.

The undersigned has carefully examined the Contract Documents for the City of Dawson Creek RFQ 2012-04.

Company Representative (signature)

X _____

Name/Title: _____

Date: _____